

<b>SCOTTS VALLEY FIRE PROTECTION DISTRICT</b>		
<b>STANDARD OPERATING PROCEDURES</b>	<b>ARTICLE: II</b>	<b>SOP: 2207</b>
	<b>SECTION: 2200 APPARATUS AND EQUIPMENT</b>	
	<b>SUBJECT: APPARATUS HOSE INVENTORY</b>	

**Purpose :** To assure a consistent hose inventory is maintained on all apparatus and to comply with or exceed the requirements established in the FireScope FOG manual regarding resource typing and minimum inventory standards.

**Scope:** Apparatus inventory will not be adjusted without the approval of the operations division. Seasonal inventory adjustments are also subject to the approval of the operations division.

**Definitions:**

*Structure hose pack -*

Hose pack with 100' of 1 1/2" or 1 3/4" Rubber (Angus) or double jacketed hose with a 100 gpm or greater fog nozzle.

*Wildland Pack -*

Donut hose roll 100' of 1 1/2" SJ - 2 each per pack with 1" tees (water thief) attached.

*1" hose pack -*

Double donut roll with 100' of 1" SJ forestry hose NPT and nozzle.

*Live line -*

Pre-connected to a discharge

*Transverse line -*

Pre-connected live line normally over the top of a mid-ship pump.

*Commercial set -*

150' 1 3/4" hose connected to the 2 1/2" hose bed via a 2 1/2" x 1 1/2" wye.

<b>10/23/01</b>	<b>APPROVED:</b> 	<b>PAGE 1 OF 2 PLUS 2 ATTACHMENTS</b>
-----------------	---	---

<b>SCOTTS VALLEY FIRE PROTECTION DISTRICT</b>		
<b>STANDARD OPERATING PROCEDURES</b>	<b>ARTICLE: II</b>	<b>SOP: 2207</b>
	<b>SECTION: 2200 APPARATUS AND EQUIPMENT</b>	
	<b>SUBJECT: APPARATUS HOSE INVENTORY</b>	

*LDH -*

Supply or distribution hose exceeding 3" in diameter. *LDH can be used in place of 2 1/2" hose in fulfilling FOG inventory requirements.*

**Procedure:**

See attachments 2207a and 2207b.

<b>10/23/01</b>	<b>APPROVED:</b> 	<b>PAGE 1 OF 2 PLUS 2 ATTACHMENTS</b>
-----------------	---	---